



ODISHA RENEWABLE ENERGY DEVELOPMENT AGENCY
Under the Department of Science & Technology
Government of Odisha

(ISO 9001:2008 / ISO 14001:2004)
S/59, MANCHESWAR INDUSTRIAL ESTATE
BHUBANESWAR-751010, ODISHA

Website : www.oredaorissa.com E-mail : ceoreda@oredaorissa.com

No..... /OREDA

Dated 2016

Corrigendum to the "e" Tender Call Notice No. 3152 dt.26.07.2016

The amendments are made to the tender as follows:

S/N	Reference	Page No.	Previously mentioned	Read as/Amendment
1	Technical specification 10 KW solar power plant	31	The Earthing for array and distribution system & Power plant equipment shall be made with GI pipe, 4.5 m long 40 mm diameter	The Earthing for array and distribution system & Power plant equipment shall be made with GI pipe, 1.5 m long 40 mm diameter
2	Technical specification 14 KW solar power plant-PCU	37	Output voltage: 1 Phase, 230 V ac (+/- 20 %)	Output voltage: 3 Phase, 415 V ac (+/- 20 %)
3			The DC energy produced has to be utilized to maximum and supplied to the bus for inverting to AC voltage to extract maximum energy from solar array	The DC energy produced has to be utilized to maximum and supplied to the bus for inverting to AC voltage to extract maximum energy from solar array
4	Technical specification 14 KW solar power plant	38	The Earthing for array and distribution system & Power plant equipment shall be made with GI pipe, 4.5 m long 40 mm diameter	The Earthing for array and distribution system & Power plant equipment shall be made with GI pipe, 1.5 m long 40 mm diameter

Chief Executive

[Signature]
20/8/16