



ODISHA RENEWABLE ENERGY DEVELOPMENT AGENCY

(Under Science & Technology Department, Government of Odisha)

S-3/59, Mancheswar Industrial Estate, Bhubaneswar-751010

Ph: 91-674-2588260, Fax: 2586368

Web site: www.oredaorissa.com E-mail: ceoreda@oredaorissa.com

Corrigendum to the "e" Tender Call Notice No. 5021/OREDA DTD- 28-11-2016

Subsequent upon discussion had in the pre-bid meeting on 08.12.16, following amendment to the bid document is made which may be adhered to.

S/ N	Reference	Page No.	Previously Mentioned	Read as/Amendment
1	Technical Specification-Battery (For Household)	322	The battery should be 48V, 42 AHr Battery array	The battery should be 4 No. of 12V, 42 AHr Battery array
2	Technical Specification-Battery (For Street light)	334	48 V, 5 Ahr (App. 150 Watt-Hour) Lithium Ferro phosphate - 90% DoD or 48 V, 10 Ahr, (Appr. 300 watt-hour) with Lead-Acid Sealed maintenance free VRLA 50% DoD.	12 V, 20 Ahr (App. 150 Watt-Hour) Lithium Ferro phosphate - 90% DoD or 12 V, 40 Ahr, (Appr. 300 watt-hour) with Lead-Acid Sealed maintenance free VRLA 50% DoD.

By order of Chief Executive

Sd-
Deputy Director (Tech)
OREDA