



ODISHA RENEWABLE ENERGY DEVELOPMENT AGENCY

S-3/59, MANCHESWAR INDUSTRIAL ESTATE, BHUBANESWAR-751010

Phone: (0674) 2588260, 2586398, 2580554, Fax: 2586368

Website: www.oredaorissa.com , Email: ceoreda@oredaorissa.com

No: 1121

Date: 09/03/2021
PD-26/2018.

Addendum-1 to the Notice Inviting Tender No 778 dated 18.02.2021 invited for Design, Engineering, Supply, Installation and Commissioning of Rooftop Solar Power System (RSPS) along with Comprehensive Maintenance for five (5) years at various Health Institutions across the State

In view of the queries received from the bidder(s), following amendments have been carried out in Notice Inviting Tender No 778 dated 18.02.2021 invited for Design, Engineering, Supply, Installation and Commissioning of Rooftop Solar Power System (RSPS) along with Comprehensive Maintenance for five (5) years at various Health Institutions across the State.

All other conditions remain unchanged.

The Addendum is given at Annexure-A:


Chief Executive

Memo No. 1122 /OREDA

Date 09/03/2021

Copy forwarded to the Principal Secretary, Energy Department, Govt. of Odisha for favour of information.


Chief Executive

Memo No. 1123 /OREDA

Date 09/03/2021

Copy forwarded to the Joint Secretary, Health & Family Welfare Department, Govt. of Odisha for favour of information.


Chief Executive

9/3/2021

File

Memo No. 1154 /CRESDA

Date 09/03/2021

Copy forwarded to M/S RESONICS, A Govt. of Karnataka Undertaking, No.29/1, Race course Road, Bangalore-560 001 for information and necessary action.


Chief Executive

Memo No. 1155 /CRESDA

Date 09/03/2021

Copy forwarded to the Director (Admin) / All Divisional Heads / Publicity Wing / Notice Board / Website of CRESDA i.e. www.cresdaofisha.com for information and necessary action.


Chief Executive
9/3/21

Addendum-1 to the Notice Inviting Tender No 778 dated 18.02.2021 invited for Design, Engineering, Supply, Installation and Commissioning of Rooftop Solar Power System (RSPS) along with Comprehensive Maintenance for five (5) years at various Health Institutions across the State

S/N	Reference	Page no.	Current provisions	Amendments
1	Technical Specification	69	PCU Ingress Protection for Outdoor/Indoor Enclosure: 65/56	PCU Ingress Protection for Outdoor/Indoor Enclosure: 21
2	Technical Specification	92	Each Junction Box shall have High-quality Suitable capacity Metal Oxide Varistors (MOVs) / SPDs. The Junction Boxes shall have suitable arrangement monitoring and disconnection for each of the groups.	Each Junction Box shall have High-quality Suitable capacity SPDs (Type-II). The Junction Boxes shall have suitable arrangement monitoring and disconnection for each of the groups.
3	Technical Specification: REMOTE MONITORING SYSTEM	98	The Solar PV Power plant must be provided with a remote monitoring system embedded in the Generation Meter. The RMS must be capable of providing ONLINE Generation data (daily, monthly, yearly & total). The features of the RMS along with operational details must be submitted along with the Bid.	The Solar PV Power plant must be provided with a remote monitoring system embedded in the Generation Meter for the On-Grid Solar Power Plant projects . For Off-Grid project, the Remote Monitoring System in Solar Inverter must be provided along with the RSPS. It should be capable of providing all relevant data of Inverter like ONLINE Generation data (daily, monthly, yearly & total), Power, Consumption date, Alerts etc.
4	Appendix Form 1 7.5.1.1/a	90	The solar PV modules to be used shall be made in India only. The PV modules shall qualify for the latest edition of the IEC PV module qualification test or equivalent BIS standards of crystalline silicon solar cell modules IEC 61215 and IS14286.	The solar PV modules to be used shall be made in India only. The PV modules shall qualify for the latest edition of the IEC PV module qualification test or equivalent BIS standards of crystalline silicon solar cell modules IEC 61215/IS14286 .
5	BDS 2.18 ITB, 1.6.3.3	26	The Performance Security shall be submitted for an aggregate amount equivalent to ten percent (10%)	The Performance Security shall be submitted for an aggregate amount equivalent to 3 percent (3%) .
6	Appendix Form 1 7.5.1.6./a,iii	96	Similarly Type I+II SPD should also be provided on the grid side in ACDB or PCU to protect the PCU from damage	Similarly Type II SPD should also be provided on the grid side in ACDB or PCU to protect the PCU from damage.

Reference	Page no.	Current provisions	Amendments
7	35	Applicability: For Category A Bidders only The Bidder must have an minimum average annual turnover of not less than 2.00 (Two) Crore INR in the last three (3) financial years from FY16-17, FY17-18 and FY18-19 from the solar business only.	Applicability: For Category A Bidders only The Bidder must have an minimum average annual turnover of not less than 2.00 (Two) Crore INR in the last three (3) financial years from FY17-18, FY18-19 and FY19-20 from the solar business only.
8	35	Applicability: For Category A Bidders The Bidder must have a positive net worth in the last financial year FY18-19.	Applicability: For Category A Bidders The Bidder must have a positive net worth in the last financial year FY19-20 .
9	34	Applicability: For Category A Bidders only The Bidder must have the cumulative experience of commissioning RSPS and/or Mini Grid Projects for minimum capacity of 250 KW in the last five (5) years from the last date of online submission of the Technical Bid in Odisha.	Applicability: For Category A Bidders only The Bidder must have the cumulative experience of commissioning RSPS and/or Mini Grid Projects for minimum capacity of 200 KW in the last five (5) years from the last date of online submission of the Technical Bid in Odisha.
10	2	Due date and time for submission of online copies of Technical Bid and Price Bid: [17.03.2021], Time: 5:00 PM	Due date and time for submission of online copies of Technical Bid and Price Bid: [23.03.2021], Time: 5:00 PM
		Due date and time for submission of hard copies of Technical Bid for select Bid Forms only: [19.03.2021], Time: 1:00 PM	Due date and time for submission of hard copies of Technical Bid for select Bid Forms only: [25.03.2021], Time: 1:00 PM
		Due date and time for the opening of Technical Bid for both online copies and hard copies, except Price Bid: [19.03.2021], Time: 3:00 PM	Due date and time for the opening of Technical Bid for both online copies and hard copies, except Price Bid: [25.03.2021], Time: 3:00 PM