



ODISHA RENEWABLE ENERGY DEVELOPMENT AGENCY
Under the Department of Energy
Government of Odisha
(ISO 9001:2008 / ISO 14001:2004)
S/59, MANCHESWAR INDUSTRIAL ESTATE
BHUBANESWAR-751010, ODISHA

Website : www.oredaodisha.com E-mail : ceoreda@oredaorissa.com

Letter No 2594/OREDA

Dated. 16/8 | 2023

Corrigendum to the e-tender Notice No- 2295 dated 19th July 2023 for Design, Engineering, Supply, Installation, Testing and Commissioning of "Roof top Solar Power System at 21 Tehsil offices in Odisha" along with Comprehensive Maintenance for Five (5) years.

It is for information of all concerned that, in view of the queries received from the bidder(s), following Corrigendum, Addendum and clarification have been carried out in the e-tender Notice No – 2295/OREDA, dated 19.07.2023.


Extension of date of the schedule of Events:

Sl No.	Name of Event	As mentioned in e-tender Notice	Proposed Amendment
1	Date of publication of RFP on E-procurement website and OREDA website	20-07-2023	20-07-2023
2	Due date of pre bid query submission	26-07-2023 up to 5.00 PM	26-07-2023 up to 5.00 PM
3	Date and time of pre-bid meeting through virtual mode https://meet.google.com/mja-vcvr-dos	01-08-2023 at 11.30 AM	01-08-2023 at 11.30 AM
4	Due date and time for submission of online copies of Technical Bid and price bid.	17-08-2023 up to 5.00 PM	25-08-2023 up to 5.00 PM
5	Due date and time for submission of hard copies of Technical Bid for select Bid Forms only	21-08-2023 up to 1.30 PM	28-08-2023 up to 1.30 PM
6	Due date and time for the opening of Technical Bid for both online copies and hard copies, except price bid.	22-08-2023 at 3.30 PM	31-08-2023 at 3.30 PM
7	Due date and time for the opening of online price bid applicable only for the bidders whose Technical bids shall be responsive.	To be intimate later	To be intimate later

All the prospective bidders are advised to kindly keep referring www.tenderwizard.com/OREDA and www.oredaorissa.com website for periodic updates.

All other terms and conditions of the original tender document shall remain unchanged.

Yours Faithfully



16.08.2023

Chief Executive

Memo No. 2595 /OREDA

Date 16/8 /2023

Copy forwarded to The Additional Chief Secretary, Revenue & Disaster Management Department, Govt. of Odisha for kind information.



16.08.2023

Chief Executive

Memo No. 2596 /OREDA

Date 16/8 /2023

Copy forwarded to M/S KEONICS, A Govt. of Karnataka Undertaking, No.29/1, Race course Road, Bangalore- 560 001 for information and necessary action.



16.08.2023

Chief Executive

Memo No. ⁽⁶⁾2597 /OREDA

Date 16/8 /2023

Copy forwarded to the Director (Admin) / All Divisional Heads / Publicity Wing / Notice Board / Website of OREDA i.e. www.oredaodisha.com for information and necessary action.


16.08.2023

Chief Executive

Addendum/Clarification to the e-tender Notice – 2295, dated 19.07.2023

Design, Engineering, Supply, Installation, Testing and Commissioning of 802 kW Solar power projects along with Comprehensive Maintenance for Five (5) years at 21 Tehsil offices in Odisha.

Clarification on queries raised during pre-bid meeting on 1/08/2023

NIT no: 2295

Dated 19/07/2023

Sl. No.	Page no.	RFP/PPA clause no. and Description	Existing Clause	Clarification sought	Clarification issued by OREDA	Addendum
1	93	7.5.1.4. Power Conditioning Unit (PCU)	PCU requirement description with sub clause 7.5.1.4. a) and 7.5.1.4. b)	In the above mentioned tender, the inverter is mentioned as Hybrid one, as the system is without battery kindly it is our request to revise the same with On-Grid Inverter.	The inverter type is On-Grid Inverter without Battery backup.	7.5.1.4. b) stands deleted. Inverter shall provide display of PV array DC voltage & current, Inverter Voltage & Current, Grid voltage & Current, and required parameters when a fault occurs. Remote monitoring of inverter parameters should be available.